



Microbac Laboratories, Inc. - Chicagoland

CERTIFICATE OF ANALYSIS

C4J0021

Project Description

Special Blessings Chlidcare

For:

Aija Putelis

120 Water

250 S. Elm St

Zionville, IN 16077

Customer Relationship Coordinator

Bianca Svetich

Thursday, October 3, 2024

Please find enclosed the analytical results for the samples you submitted to Microbac Laboratories. Review and compilation of your report was completed by Microbac Laboratories, Inc. - Chicagoland. If you have any questions, comments, or require further assistance regarding this report, please contact your service representative listed above.

I certify that all test results meet all of the requirements of the accrediting authority listed within this report. Analytical results are reported on a 'as received' basis unless specified otherwise. Analytical results for solids with units ending in (dry) are reported on a dry weight basis. A statement of uncertainty for each analysis is available upon request. This laboratory report shall not be reproduced, except in full, without the written approval of Microbac Laboratories. The reported results are related only to the samples analyzed as received.

Microbac Laboratories, Inc.

250 West 84th Drive | Merrillville, IN 46410 | 219.769.8378 p | www.microbac.com



Microbac Laboratories, Inc. - Chicagoland

CERTIFICATE OF ANALYSIS

C4J0021

120 Water

Aija Putelis
250 S. Elm St
Zionville, IN 16077

Project Name: Special Blessings Chlidcare

Project / PO Number: KS_LIF_2021

Received: 09/26/2024

Reported: 10/03/2024

Sample Summary Report

<u>Sample Name</u>	<u>Laboratory ID</u>	<u>Client Matrix</u>	<u>Sample Type</u>	<u>Sample Begin</u>	<u>Sample Taken</u>	<u>Lab Received</u>
445622 - 101	C4J0021-01	Drinking Water	Grab		09/23/24 06:56	09/26/24 14:57
445623 - 102	C4J0021-02	Drinking Water	Grab		09/23/24 06:57	09/26/24 14:57
445624 - 103	C4J0021-03	Drinking Water	Grab		09/23/24 06:59	09/26/24 14:57
445625 - 104	C4J0021-04	Drinking Water	Grab		09/23/24 07:01	09/26/24 14:57
445626 - 105	C4J0021-05	Drinking Water	Grab		09/23/24 07:02	09/26/24 14:57
445627 - 106	C4J0021-06	Drinking Water	Grab		09/23/24 07:00	09/26/24 14:57



Microbac Laboratories, Inc. - Chicagoland

CERTIFICATE OF ANALYSIS

C4J0021

Analytical Testing Parameters

Client Sample ID:	445622 - 101	
Sample Matrix:	Drinking Water	
Lab Sample ID:	C4J0021-01	Collection Date: 09/23/2024 6:56

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	<1.00	1.00	ug/L	1			10/02/24 1833	MCD

Client Sample ID:	445623 - 102	
Sample Matrix:	Drinking Water	
Lab Sample ID:	C4J0021-02	Collection Date: 09/23/2024 6:57

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	<1.00	1.00	ug/L	1			10/02/24 1834	MCD

Client Sample ID:	445624 - 103	
Sample Matrix:	Drinking Water	
Lab Sample ID:	C4J0021-03	Collection Date: 09/23/2024 6:59

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	9.88	1.00	ug/L	1			10/03/24 1015	MCD

Client Sample ID:	445625 - 104	
Sample Matrix:	Drinking Water	
Lab Sample ID:	C4J0021-04	Collection Date: 09/23/2024 7:01

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	<1.00	1.00	ug/L	1			10/02/24 1836	MCD

Client Sample ID:	445626 - 105	
Sample Matrix:	Drinking Water	
Lab Sample ID:	C4J0021-05	Collection Date: 09/23/2024 7:02

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	<1.00	1.00	ug/L	1			10/02/24 1837	MCD



Microbac Laboratories, Inc. - Chicagoland

CERTIFICATE OF ANALYSIS

C4J0021

Client Sample ID: 445627 - 106
Sample Matrix: Drinking Water
Lab Sample ID: C4J0021-06

Collection Date: 09/23/2024 7:00

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	11.9	1.00	ug/L	1			10/03/24 1016	MCD

Definitions

RL: Reporting Limit
ug/L: Micrograms per Liter

Cooler Receipt Log

Cooler ID: Default Cooler Temp: °C

Comments

Samples preserved at lab on 9/26/24 @1457 by QR

Cooler Inspection Checklist

Ice Present or not required?	Yes	Shipping containers sealed or not required?	Yes
Custody seals intact or not required?	Yes	Chain of Custody (COC) Present?	Yes
COC includes customer information?	Yes	Relinquished and received signature on COC?	Yes
Sample collector identified on COC?	Yes	Sample type identified on COC?	Yes
Correct type of Containers Received	Yes	Correct number of containers listed on COC?	No
Containers Intact?	Yes	COC includes requested analyses?	Yes
Enough sample volume for indicated tests received?	Yes	Sample labels match COC (Name, Date & Time?)	Yes
Samples arrived within hold time?	Yes	Correct preservatives on COC or not required?	Yes
Chemical preservations checked or not required?	Yes	Preservation checks meet method requirements?	No
VOA vials have zero headspace, or not recd.?	Yes		

Project Requested Certification(s)

Microbac Laboratories, Inc. - Chicagoland
E-10397

Kansas Department of Health and Environment

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.

Reviewed and Approved By:

Bianca Svetich
Customer Relationship Coordinator
Reported: 10/03/2024 15:30



120Water
PM: Blanca Svetlich

6450021

Chain of Custody

Chain of Custody (CoC) Instructions: The CoC is an official record that accounts for your water samples and must be filled out. You can either collect samples with your 120Water account or by using this form. If you collect samples within your 120Water account, simply fill out section 1 and use return to lab shipping label included in kit and drop kit off at post office. If you use this form to collect samples, fill out both sections 1 and 2, make sure to write down the time you collected each sample and then use return to lab shipping label included in kit and drop kit off at post office. Have questions? Call 800.674.7961 or email support@120water.com

Name: Special Blessings Childcare
ID: N/A
Event ID: 11456
nt ID: 116 - Kansas LIF

SECTION 1 MUST BE COMPLETED (even if you collect samples with your 120Water account)

Sampling Date (MM/DD/YYYY): 09/23/2024	Sample Collector's Email: specialblessings4@gmail.com
Sample Collector(s) Name (s) (Please Print): Blanca Svetlich	Sample Collector's Phone: 620-344-8003
Sample Collector(s) Signature: 	When was water last used in the building? DATE: 09/22/2024 TIME: 7:00 p.m.
Did you collect samples within your 120Water account? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO, I will use this form	

SECTION 2 (NEXT PAGE) MUST BE COMPLETED IF YOU USE THIS FORM TO COLLECT SAMPLES

If you use this form to collect samples (instead of collecting within the 120Water platform) you must write the time each sample was collected in Section 2.

RECEIVED IN LAB BY:		DATE: 9/26/24	TIME: 12:00
WORK ORDER: USps NI - Samples preserved & lab on 9/26/24 @ 1457 by QR		Lab Reporting: Email EDD to results@120water.com	
Matrix: DW-Lead		Analyte: Total Lead	
Sample Type: Grab			

Section 2 (Starting Here) Must be Completed if you use this Form to Collect Samples - N/A							
Sample Code	Fixture Code	Sample Type	Location	Location Description	Fixture Type	Time Sample Collected	Notes
445622	101	Initial	Upstairs Kitchen	→ top floor	Faucet, Cold	6:56 AM	
445623	102	Initial	Upstairs Bathroom	→ Basement	Faucet, Cold	6:57 AM	
445624	103	Initial	Outside Faucet north side of house	→ outside North house	Spigot	6:59 AM	
445625	104	Initial	Downstairs in child care laundry room	→ Downstairs in child care	Faucet, Cold	7:01 AM	
445626	105	Initial	Bathroom sink in Child Care	→ Downstairs in child care	Faucet, Cold	7:02 AM	
445627	106	Initial	South side of house Outdoor Faucet	→ Outside South of house	Spigot	7:00 AM	